

Ref: AADC/100/45/579

Date: 27/02/2012

To : VERGER et DELPORTE U.A.E. Ltd.

Subject : Approval of LV Switchgears Materials

With reference to the above mentioned subject and your letter # (AADC/VER/SGD-S/3) dated 12/02/2012, please be informed after reviewing and studying the submitted documents & attested copies of the ASEFA type test certificates of your LV products, the following items have been approved by AADC as per details & conditions:

S/N	Product Type & Reference Power switchgear and control gear assembly	Rating	Certificate No	Laboratory	Manufacturer Country of Origin
1.	CAMGRO SYSTEM 4000A Main Distribution Board / MCC	4000 A	ASEFA 129c-11BT	L2E: Expertise and testing Laboratory France	Verger et Delporte U.A.E. Ltd. Sharjah ,UAE
2.	CAMGRO SYSTEM 6000A Main Distribution Board / MCC	6000A	ASEFA 130a-11BT	L2E: Expertise and testing Laboratory France	

- 1. The above approval does not relieve the Contractors in complying with last revision of RSB wiring regulation and AADC standards that are applied to the LV Switchgear and Panel Boards, including the environmental conditions & prospective fault currents have been specified in this regulation.
- 2. The products shall comply with the latest recommendations of the relevant standards IEC 61439-1&2.
- 3. Rated diversity factor of all outgoing busbars & its protective devices must be not less than (1).
- 4. All the breakers (both the incoming and outgoing) shall be restricted to the components used in the test or to be tested by any of the approved certified authorities



- 5. This approval is subject to all technical & environmental conditions have been specified in electricity wiring regulation 2009 issued by RSB.
- 6. Certificate of conformity must be submitted for every switchgear assembly.
- 7. The manufacturer shall submit to AADC the performance reports for installed products for a period of 3 years, any damage or malfunction during this period may lead to the cancellation of AADC approval.

Regards,

Mubarak Al Shamsi Customer Services Director

Cc:

- Services Support Department
- Power Services Section
- E&S Unit
- File